

GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From
Regional Fire Officer,
Hyderabad region,
Hyderabad.
Telangana

To
Sri.P Haragopal,
Survey No.268,
Raghavendra nagar,
Athvelly(V), Medchal(M).
Medchal-Malkajgiri District, Telangana.

Re. No. 035/RFO/HYD/2019, DATED: 31.08.2020

Sir,

Sub: Telangana State Disaster Response & Fire Services Department- Issue of No Objection Certificate for Occupancy to the Existing Educational Building of Sri P Haragopal, Survey No.268 Raghavendra nagar, Athvelly(V), Medchal(M), Malkajgiri-Medchal District-Reg.

Ref:- 1) Letter Rc.No Nil, Dt. 01.07.2019 Of Sri.P Haragopal, Survey No. 268 Raghavendra Nagar, Athvelly(V), Medchal(M), Medchal-Malkajgiri District, Telangana.
2) Inspection Report of Station Fire Officer, Medchal Dt. 29.08.2020

\$\$\$\$\$

With reference 1st cited, the Authorized representative has reported that He has constructed Educational Building without obtaining Provisional No-Objection Certificate from this Department and requested to issue the No-Objection Certificate for Occupancy to the Existing Educational building Hi-Tech Scholars Residential High School of Sri P. Haragopal, Survey No. 268 Raghavendra Nagar, Athvelly(V), Medchal(M), Medchal-Malkajgiri District, Telangana.

2) Vide reference 2nd cited, the Station Fire Officer Medchal, has inspected the existing Educational Building on 29-08-2020 and recommended for issue Of No Objection Certificate For Occupancy for the above Building.

3) Particulars of Educational Building:-

i) Height of the building 10.03 meters.

ii) Open spaces:

Direction	Required as per NBC-2005	Provided	Deficit/Remarks
North	06.00 Meters	N.A	N.A
East	06.00 Meters	N.A	N.A
South	06.00 Meters	N.A	N.A
West	06.00 Meters	N.A	N.A

iii) Floor wise particulars:

Sl.No	Floor	Floor Area In Sq.Meters	Occupancy	Maximum Occupancy Load as per NBC,2005
1	Ground Floor	557.67 Sq.Mtrs	Educational	60
2	First Floor	553.67 Sq.Mtrs	Educational	60
3	Second Floor	557.62 Sq.Mtrs	Educational	60
	Total	1672.96Sq.Mtrs	--	180

The Management has remitted fire precaution fee for Rs.25800=00 (Rupees Twenty Five Thousands Eight Hundred Only) Vide Challan No.17352 dated: 05.03.2019 S.B.I Gruhakalpa Branch, Hyd.

iv) Means of escape:

Sl.no	Details of staircase	Provided		Deficit
		No's	Width in	
1	Internal staircase	02 no	84.00 meters	Nil
	Total	02 Nos	84.00 Meters	

Anuladha
PRINCIPAL
HI-TECH SCHOLARS RESIDENTIAL SCHOOL
MEDCHAL, R.R. Dist.

For HI-TECH SCHOLARS RESIDENTIAL SCHOOL
P. Haragopal
Secretary / Correspondent

v) Details of Occupant load per unit Exit Width in each floor.

SI.No	Floor	Builtup Area In Sq.Meters	No.of Occupants	Means of Escape as per NBC,2005	Provided
1	Ground Floor	557.67 Sq.Mtrs	60	Y	y
2	First Floor	553.67 Sq.Mtrs	60	Y	Y
3	Second Floor	557.62 Sq.Mtrs	60	Y	Y
	Total	1672.96Sq.Mtrs	180		

4) The following fire fighting system provided by the builder as per Table-23 of N.B.C. Part-I


SI.No.	Fire Safety measures	Required as per Table 23 of NBC of	Provided	Deficiency
1	Fire Extinguishers	40 Nos	40 Nos	Nil
2	Down Corner	02 Nos	02 Nos	Nil
3	Hose Reel	06 Nos	06 Nos	Nil
4	a)Terrace Tank capacity 10,000 Ltrs b)Additional 5,000Ltrs if area of basement area Exceeded	20000ltrs	20000ltrs	Nil
	a)One Booster pump of 450 LPM b) One Booster pump of	900 LPM	900 LPM	Nil

5) Therefore this Office has No Objection for Occupancy to the Existing Educational Building of Sri P. Haragopal, Survey No. 268, Raghavendra Nagar, Athvelly(V), Medchal(M), Malkajigiri District, Telangana.

i	All the fire protection arrangements shall be maintained in good repair as seen during inspection
ii	All the escape/exit routes shall not be kept locked/blocked or encroached
iii	A installed ll the occupants must know the correct method of operation of the fire fighting system
iv	Any loss of life or property due to non-functioning of the fire safety measures and other installation shall be the responsibility of the management.
v	All the students/staff members of the institution shall be trained to operate the fire safety equipments during emergency.
vi	Addition/alteration, if any in the building may be obtained with prior permission from this department.
viii	Mock drills should be conducted once in 3 months for initial two years Thereafter, once in every 6 months.

This occupancy clearance is valid for the period of One year from the date of Issue.

Yours faithfully,


Regional Fire Officer
Hyderabad Region,
Hyderabad.

Copy to the Station Fire Officer, Medchal.
Copy to Sri P. Haragopal, Survey No. 268, Raghavendra Nagar,
Athvelly(V), Medchal(M), Malkajigiri District, Telangana.

PRINCIPAL
HI-TECH SCHOLARS RESIDENTIAL SCHOOL
MEDCHAL, R.R. Dist.

For HI-TECH SCHOLARS RESIDENTIAL SCHOOL


Secretary / Correspondent